

Certificate of Assessment

Job No.: NK7608

No. 2289

"Copyright CSIRO 2016 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Infrastructure Technologies in accordance with Australian/ New Zealand Standard 3837, Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter, 1998, at 50 kW/m², on behalf of:

Perma Composites Pty Ltd
14 Garino Rise
WANGARA WA 6065
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNK 11699.

SAMPLE

IDENTIFICATION: Perma Timber Quickboard

DESCRIPTION OF SAMPLE:

The sponsor described the tested specimen as an extruded hollow laminated decorative PVC wall and ceiling lining panel. The specimen has a hollow cross section with ribbing spaced at 10-mm centres.

Nominal wall thickness: 0.3 mm
Nominal rib thickness: 0.1 mm
Nominal total thickness: 7 mm
Nominal mass: 2.7 kg/m²
Colour: light brown (cedar timber - decorative face)

SAMPLE

CLASSIFICATION: Group Number: Group 1
(In accordance with Specification A2.4 of the Building Code of Australia.)^{1,2}

Average specific extinction area: 527.2 m²/kg
(Refer to Specification C1.10 section 4(c) of the Building Code of Australia.)^{1,2}

Notes:

1. The results of this fire test may be used to directly assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all fire conditions.
2. As per Section 9 (n) of AS 5637.1:2015, the determination of the group number was based on the AS/NZS 3837:1998 test, and was deemed valid in the cone calorimeter for the assignment of National Construction Code (NCC) group number.

Testing Officer: Heherson Alarde Date of Test: 2 May 2016

Issued on the 31st day of May 2016 without alterations or additions.


Brett Roddy

Team Leader, Fire Testing and Assessments



NATA Accredited Laboratory
Number: 165
Corporate Site No 3625
Accredited for compliance with ISO/IEC 17025.

CSIRO INFRASTRUCTURE TECHNOLOGIES

14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555 www.csiro.au

